

Temperature Log

The Jikei University Hospital

Location : Pharmaceutical department

Acceptable Temperature Range : 2°C to 8°C

Refrigerator/Freezer Name: MPR-514-PJ

Thermometer Device/ID: FS Traceable/230735257(Expiry date : 01 Nov 2025)

Date 日付	Time 確認時間	Current 確認時の 温度	Min 最低温度	Max 最高温度	Initials (確認者)
01 Oct 2025	9 : 20	5.7	3.9	6.3	S.H
02 Oct 2025	9 : 30	4.9	4.1	6.1	S.H
03 Oct 2025	9 : 00	5.8	4.1	6.1	S.H
04 Oct 2025	9 : 15	4.1	4.0	6.4	P-Y
05 Oct 2025	:				
06 Oct 2025	9 : 15	5.6	4.0	6.1	S.H
07 Oct 2025	9 : 40	4.1	4.0	6.1	Y.N
08 Oct 2025	9 : 15	4.3	4.0	6.1	S.H
09 Oct 2025	9 : 00	5.0	4.3	6.2	S.H
10 Oct 2025	9 : 00	6.0	4.3	6.1	S.H
11 Oct 2025	:				
12 Oct 2025	:				
13 Oct 2025	:				
14 Oct 2025	9 : 00	6.1	4.5	6.2	S.H
15 Oct 2025	9 : 00	6.1	4.5	6.1	S.H
16 Oct 2025	9 : 00	6.0	4.4	6.2	S.H
17 Oct 2025	9 : 00	4.9	4.4	6.2	P-Y
18 Oct 2025	8 : 30	5.2	4.0	6.1	S.H
19 Oct 2025	:				
20 Oct 2025	9 : 30	6.0	4.0	6.1	P-Y
21 Oct 2025	10 : 10	4.2	4.0	6.1	S.H
22 Oct 2025	9 : 05	4.7	4.0	6.1	P-Y
23 Oct 2025	9 : 10	4.7	4.0	6.1	S.H
24 Oct 2025	11 : 00	4.8	3.8	6.2	S.H
25 Oct 2025	9 : 00	5.9	3.8	6.2	S.H
26 Oct 2025	:				
27 Oct 2025	8 : 40	5.9	3.7	6.0	Y.N
28 Oct 2025	8 : 40	5.8	3.7	6.0	Y.N
29 Oct 2025	8 : 30	6.1	3.8	6.2	S.H
30 Oct 2025	14 : 00	4.4	4.0	6.4	Y.N
31 Oct 2025	10 : 30	5.5	4.0	6.2	S.H

Investigational Product Manager's Signature:

Shunsuke Hitosugi

Date: 01-Nov-2025